

Controller of Stores & Disposal (South), PSPCL, Patiala

E - Auction Notice No. - EA/13/PTA-13
Date of Auction - 25.6.2013

Following Scrap Material is Offered for On-Line Forward E-Auction at the above mentioned date as per the prevailing PSPCL's Terms & Conditions of the E-Auction Sale (available on PSPCL web site www.pspcl.in) on "As - Is - Where - Is " basis.

A - Damaged Distribution Transformers As Per Actual Site Condition

NOTE : Before lifting of Transformers (From Lot no. A 1 to A 22), HT/LT copper winding coils of transformers shall be mutilated by the purchaser.

Lot No. A 1 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY MALOUT

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
13	16	6.3 KVA	MS-4, ARD-1, HR-2, NPC-4, SEF-1, PBN-1, JB-3	975
14	16	6.3 KVA	MS-5, ARD-1, HR-1, NPC-2, SEF-2, JB-2, PTEL-3	961
15	16	6.3 KVA	MS-2, NPC-4, DRBL-4, PP-1, JB-5	978
29	16	16 KVA	MS-8, TA-1, PP-1, UTTAM-4, S.SAHKTI-1, NSL-1	1878
32	25	10 KVA	Sushil-1, MCPL-2, JB-1, PAN-1, HR-2, MS-9, Muskan-1, SkywAY-4, Ard-1, Uttam-2, PTEL-1	2101
36	18	16 KVA	PAN-1, MS-6, Shiv Shakti-4, Saraf-1, Muskan-1, Uttam-05	2106
11	16	6.3 KVA	MS-3, HR-6, NPC-4, SEF-1, PP-1, HI TECH-1	983
12	16	6.3 KVA	MS-6, ARD-1, HR-2, NPC-3, SEF-2, PP-1, JB-1	972
5	16	6.3 KVA	MS-4, NPC-1, SEF-1, SIC-1, PBN-6, JB-2, MCPL-1	951
6	16	6.3 KVA	MS-3, HR-6, NPC-2, PBN-1, JB-3, MCPL-1	966
19	16	6.3 KVA	MS-3, HR-2, NPC-3, DRBL-1, PP-1, PBN-1, JK-1, JB-3, MCPL-1	969
Total	187			13840

Lot No. A 2 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY FERROZEPUR

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
14	25	6.3 KVA	NUCON-5, NPC-6, PTEL-1, HI TEHC-2, SARAF-1, SIC-5, P.TECH-1, JR-1, JB-1, SKS-1, MRN-1	1500
15	25	6.3 KVA	PTEL-2, JB-2, SKS-3, MUSKAN-1, NPC-7, NUCON-2, MRN-3, HI TEHC-1, UBE-1, SUSHIL-1, GTB-1, SIC-1	1543
16	25	6.3 KVA	PTEL-1, NPC-9, SIC-6, SKS-1, PP-1, GTB-1, NUCON-4, JB-2	1516
91	20	16 KVA	JR-3, PP-4, SIC-3, UBE-3, NUCON-6, SSE-1	2040
92	20	16 KVA	NUCON-4, PP-2, SKF-1, SIC-1, UBE-4, RR-2, JR-5, DAUSA-1	2081
26	25	6.3 KVA	JB-2, SIC-3, SARAF-1, JR-5, NUCON-1, PTEL-4, NPC-4, DURABLE-3, MRN-1, S.WAY-1	1500
27	25	6.3 KVA	AMSON-1, NPC-5, MUSKAN-1, PTEL-2, JR-7, JB-3, MRN-2, SIC-2, NUCON-2	1504
28	25	6.3 KVA	JR-7, SIC-6, PTEL-3, TA-3, NPC-1, GTB-1, NUCON-1, SUSHIL-1, JB-2	1420
29	25	6.3 KVA	SIC-6, NUCON-2, PTEL-4, JR-2, NPC-7, MRN-1, JK-1, S.WAY-1, DURABLE-1	1527
86	20	10 KVA	JR-6, PTEL-1, UBE-1, NUCON-1, PP-3, NPC-2, SKS-1, AGGARWAL-2, SIC-1, SUSHIL-1, S.WAY-1	1567
87	20	10 KVA	JR-7, AGGARWAL-3, SARAF-2, SIC-3, PTEL-2, UBE-1, AMSON-1, ECO-1	1520
88	20	10 KVA	SKS-1, JR-11, SSE-1, JB-1, SUSHIL-1, UBE-1, HI TECH-1, JM-1, SIC-2	1533
30	25	6.3 KVA	SIC-4, JR-6, NPC-6, NUCON-3, MUSKAN-1, JB-1, SARAF-1, HI TECH-1, SKS-1, PTEL-1	1471
Total	300			20722

Lot No. A 3 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY MALOUT

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
37	25	6.3 KVA	JB-1,HI TECH-1,SIC-3,PTEL-1,HR-4,MS-6,DURABLE-2,PP-1,ARD-1,SARAF-1,NUCON-4	1476
38	25	6.3 KVA	PP-1,AGGRWAL-1,DURABLE-1,HR-3,MS-8, JR-3,PTEL-1,JB-1,NPC-5,SIC-1	1412
39	25	6.3 KVA	PP-2,MUSKAN-1,PAN-1,HR-2,MS-3,J.B-5, PTEL-4,PAN-1,SARAF-2,NUCON-4	1410
40	25	6.3 KVA	PAN-1,HR-4,MS-10,J.B-4,PTEL-1,PAN-1, NPC-4	1442
41	25	6.3 KVA	POWER-1,PP-1,H TECHI-1,ARD-3,HR-1,MS-10,J.B-4,PTEL-1,SARAF-2, SKYWAY-1	1442
42	25	6.3 KVA	PBN-2,NPC-2,MCPL-1,POWER-2,ARD-1, HR-6,MS-7,J.B-3,SARAF-1	1444
43	25	6.3 KVA	NPC-4,BGL-1,DURABLE-1,HR-6,MS-9, J.B-3,SARAF-1	1455
44	25	6.3 KVA	NPC-4,MCPL-2,SIC-1,PAN-1,HR-4,MS-4, J.B-8,SARAF-1	1455
45	25	6.3 KVA	NPC-3,DURABLE-1,PP-1,PBN-2,HR-7, MS-6,J.B-5	1441
46	25	6.3 KVA	NPC-6,DURABLE-2,PB-2,HR-5, MS-6, J.B-2, PTEL-1,PBN-1	1441
47	25	6.3 KVA	SKYWAY-1,SIC-1,PTEL-2,PP-2,GTB-1, SARAF-1,HR-2,MS-10,J.B-2, POWERTECH-1,MCPL-1,BGL-1	1411
48	25	6.3 KVA	SRI KRISHNA-1,MCPL-5,HR-2,MS-11, JB-1, JR-1,NPC-2,SARAF-1,PP-1	1391
49	25	6.3 KVA	NPC-3,MS-13,PTEL-1,HR-2,SICL-1, DURBLE-3,SARAF-1,MCPL-1	1416
50	25	6.3 KVA	JR-1,MCPL-1,SARAF-2,MS-8,HR-1, PTEL-3, NPC-4,BGL-1,PTEL-3,PP-1	1416
51	25	6.3 KVA	SARAF-1,MS-11,ARD-1,NPC-2,JB-4,HR-2, SIC-1,SRI KRISHNA-1,PTEL-1,PAN-1	1429
52	25	6.3 KVA	PAN-1,DURABLE-1,NPC-4,MS-12, SARAF-1,JB-3,PTEL-1,PP-2	1418
53	25	6.3 KVA	NPC-2,SARAF-3,JR-2,MS-8,DURABLE-1, PTEL-2,HR-3,PP-1,GTB-1,JB-2	1444
	425			24343

Lot No. A 4 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Malerkotla

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
57	20	10 KVA	SIC-4, NUCON-3, NPC-4, PP-2, PTEL-3, S.WAY-1 BGL-1, JR-1, PAN-1	1502
58	20	10 KVA	PTEL-5, SIC-9, HR-2, JB-1, BGL-1, MS-1, MCPL-1	1511
59	20	10 KVA	SIC-11, JR-1, HR-1, PTEL-3, PAN-1, PP-1, NUCON-2	1492
77	20	16 KVA	SIC-7, PTEL-12, MS-1	2290
78	20	16 KVA	PTEL-5, HR-2, SHIVALIK-7, MCPL-2, SIC-1, NUCON-3	2138
79	20	16 KVA	PTEL-6, SHIVALIK-10, JB-1, HR-1, NUCON-2	2111
86	20	16 KVA	SHIVALIK-12, PTEL-4, SIC-3, MS-1	2134
87	20	16 KVA	PTEL-6, SHIVALIK-8, SIC-1, SARAF-1, NUCON-3, TA-1	2105
88	20	16 KVA	SHIVALIK-11, SIC-2, PTEL-4, MS-1, NUCON-1, HR-1	2123
89	20	16 KVA	SHIVALIK-9, NUCON-2, PTEL-5, BGL-1, SIC-1, MS-1, HR-1	2134
90	20	16 KVA	SHIVALIK-8, HR-2, PTEL-1, SIC-5, MCPL-1, NUCON-1, TA-2	2164
91	20	16 KVA	SHIVALIK-9, HR-2, PTEL-6, SIC-1, NUCON-1, MS-1	2150
92	20	16 KVA	PTEL-6, SIC-3, SHIVALIK-7, TA-2,HR-2	2201
93	20	16 KVA	SHIVALIK-12, PTEL-5, MCPL-1, MS-2	2125
94	20	16 KVA	BGL-1, SHIVALIK-8, HR-3, PTEL-2, NUCON-2, SIC-1, MS-2, MUSKAN-1	2054
95	20	16 KVA	PP-1, MCPL-2, SHIVALIK-9, HR-1, PTEL-4, NUCON-2, SIC-1	2126
96	20	16 KVA	SHIVALIK-11, PTEL-5, SIC-4	2067
	340			34427

Lot No.A 5 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Sangrur

S.Report No.	No of T/Fs	Cap. KVA	in	Description	Indicative Design Wt. of Core & Winding (KG)
144	25	6.3 KVA		MRN-4, NUCON-2, PTEL-3, JB-4, SIC-8, NPC-3, WNP-1	1512
145	25	6.3 KVA		JB-3, GTB-1, SURAT-1, MRN-2, SIC-10, MUSKAN-1, STAR-2, NUCON-1, NPC-3, AMSON-1	1519
170	20	16 KVA		HARIT-1, HR-4, BGL-2, NUCON-4, UTTAM-2, SARAF-1, JB-1, M. S. -2, NPC-1, HI TEHC-1, JR-1	2186
171	20	16 KVA		HARIT-1, HR-6, BGL-2, NUCON-5, UTTAM-2, NPC-2, MS-1, SARAF-1	2185
172	20	16 KVA		PTEL-1, HR-5, NUCON-3, S.K -1, DURABLE-1, MUSKAN-1, M.S.-2, NPC-1, SIC-2, UTTAM-1, JB-1, JR-1	2197
146	25	6.3 KVA		NPC-2, MRN-2, SIC-7, HI-TECH-3, JB-4, NUCON-2, MUSKAN-2, PPI-1, PTEL-2	1521
147	24	6.3 KVA		STAR-2, ARDISON-1, MRN-4, SIC-8, PPI-1, JB-3, S.WAY-1, PTEL-1, NPC-2, MUSKAN-1	1454
173	20	16 KVA		NUCON-5, SIC-2, JR-1, HR-4, PP-1, NPC-1, S.S.-1, UTTAM-1, MS-2, MUSKAN-1, SARAF-1	2147
174	20	16 KVA		HR-7, MS-2, UTTAM-2, JB-2, NPC-2, NUCON-1, S.S.-2, SK-1, PTEL-1	2239
175	20	16 KVA		SIC-1, S.S.-1, NPC-2, HR-8, MS-7, PTEL-1	2310
161	25	10 KVA		PP-2, NUCON-1, NPC-1, BANSAL-1, HI TECH-2,	1931
178	25	10 KVA		M.SHAKTI-3, SIC-3, NPC-4, PTEL-2, JK-2, PPI-3, S.WAY-3, NUCON-1, SARAF-2, JB-1, SUSHIL-1	1962
179	25	10 KVA		NUCON-3, PPI-4, PTEL-3, GTB-1, SIC-1, MS-3, NPC-5, AMSON-1, JR-3, STAR-1	1955
180	20	10 KVA		SUSHIL-1, UTTAM-1, S.WAY-2, PTEL-1, PAN-1, JB-2, DURGA-1, NPC-2, SIC-3, HR-4, MS-1, HR-1	1628
Total	314				26746

Lot No. A 6 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Sangrur

S.Report No.	No of T/Fs	Cap. KVA	in	Description	Indicative Design Wt. of Core & Winding (KG)
162	25	10 KVA		PP-1, NUCON-2, NPC-2, BANSAL-3, JR-1, BGL-2, UTTAM-5, M.SH-2, S.WAY-3, GTB-3, JB-1	1822
163	25	10 KVA		SUSHIL-3, BGL-1, GTB-2, STAR-2, PP-2, SIC-2, S.WAY-3, STAR-1, JR-1, NPC-3, M.SHAKTI-2, PP-1, JK-2	1823
164	25	10 KVA		PP-1, NUCON-2, NPC-2, BANSAL-1, STAR-1, SARAF-1, UTTAM-1, M.S.-2, S.WAY-1, JB-2, MECA-1, GTB-1, PTEL-2, SUSHIL-3, PAN-1, JR-1, SIC-2	1893
176	20	16 KVA		JB-1, HR-7, MS-7, UTTAM-1, SIC-1, S.S.-1, BGL-1, HI TEHC-1	2289
177	20	16 KVA		SIC-3, NUCON-5, PTEL-3, BGL-2, NPC-1, JR-1, M.S.-2, PP-1, S.S.-1, HR-1	2181
Total	115				10008

Lot No. A 7. Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Barnala

S.Report No.	No of T/Fs	Cap. KVA	in	Description	Indicative Design Wt. of Core & Winding (KG)
142	25	6.3 KVA		SIC-8, PP-2, PTEL-6, NPC-2, NUCON-4, NSL-1, S.SHAKTI-1, MRN-1	1507
143	25	6.3 KVA		MRN-3, PTL-7, JK-2, NUCON-4, NPC-4, MUSKAN-1, GTB-2, JB-1, SIC-1	1524
144	25	6.3 KVA		NUCON-1, PP-2, MRN-5, MUSKAN-1, PTEL-5, STAR-2, JB-1, NPC-3, GTB-1, SIC-4	1497
155	25	10 KVA		JR-2, SIC-3, MRN-3, PP-6, NUCON-4, PTEL-3, NPC-2, UTTAM-1, SUSHIL-1	1975.3
156	25	10 KVA		PTEL-5, JR-1, SUSHIL-2, STAR-1, NPC-2, NUCON-2, JB-2, MCPL-1, MRN-1, UTTAM-5, PP-1, SKYWAY-2	2076.6
174	20	16 KVA		JR-3, HITECH-2, PP-3, SHIVSHAKTI-1, UTTAM-3, NPC-1, BGL-1, NUCON-1, SRI.K-1, JB-1 DURABLE-1, ASI-1, SARAF-1	2200.4
177	20	16 KVA		SARAF-3, PP-1, BANSAL-4, DURABLE-8, ARD-1, ASI-2, DYNAMIC-1	2229.2
158	25	10 KVA		NUCON-3, NPC-2, STAR-1, PP-2, UTTAM-3, MRN-1, SUSHIL-3, PTEL-1, JB-3, SIC-4, BGL-1, GTB-1	1977.4
175	20	16 KVA		DURABLE-6, NUCON-4, SARAF-1, M.SHAKTI-1, TA-1, PP-2, NPC-1, SIC-1, HITECH-1, SHIV.S-1, ECOPOWER-1	2120.4
Total	210				17107.3

Lot No. A 8 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Barnala

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
145	25	6.3 KVA	NPC-3, NUCON-2, MRN-2, BANSAL-1, JB-7, AMSON-2, GTB-2, SIC-3, PP-2, JK-1	1495
146	25	6.3 KVA	BANSAL-2, MRN-1, JB-6, NPC-3, NUCON-3, MUSKAN-2, SIC-5, PTEL-2, AMSON-1	1506
147	25	6.3 KVA	JB-9, SIC-2, PTEL-2, NPC-4, PP-1, AMSON-1, SUSHIL-1, MRN-2, BANSAL-1, NUCON-1, JK-1	1491
157	25	10 KVA	UTTAM-3, SUSHIL-2, JB-4, STAR-4, NPC-3, SKYWAY-2, NUCON-4, PP-2, PTEL-1	2046.4
176	20	16 KVA	SARAF-4, SKYWAY-1, DURABLE-4, PP-1, SRI.K-2, HARIT-1, M.S-1, NPC-1, BGL-1, ASI-1, UTTAM-2, PTEL-1	2173.1
Total	120			8711.5

Lot No. A 9 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Barnala

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
148	25	6.3 KVA	PP-1, JB-3, MRN-1, NPC-7, SIC-3, NUCON-3, P.TECH-2, MUSKAN-1, STAR-3, GTB-1	1521
149	25	6.3 KVA	P.TECH-1, NPC-4, MRN-3, PTEL-1, JB-7, PP-3, NUCON-3, STAR-1, SIC-2	1487
150	25	6.3 KVA	NUCON-2, SIC-1, MRN-2, BGL-1, NPC-5, JB-9, JK-1, STAR-1, PTEL-2, GTB-1	1520
159	25	10 KVA	JB-4, STAR-1, SKYWAY-2, PTEL-2, SIC-2, HITECH-1, PP-1, BANSAL-2, MRN-2, SUSHIL-4, SARAF-1, UTTAM-1, JR-1, DAUSA-1	1980.6
179	20	16 KVA	DURABLE-7, TA-1, SARAF-4, JR-1, ASI-2, ARD-1, SIC-1, BGL-2, UTTAM-1	2180.8
Total	120			8689.4

Lot No. A 10 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Barnala

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
151	25	6.3 KVA	PTEL-5, PP-1, MRN-2, JR-1, MUSKAN-1, JB-6, SARAF-3, JK-1, ASI-1, NPC-1, STAR-1, SIC-2	1465
152	25	6.3 KVA	NPC-3, JB-10, SIC-4, MRN-3, GTB-1, PTEL-2, STAR-1, NUCON-1	1478
153	25	6.3 KVA	MUSKAN-1, JK-1, SIC-5, NPC-2, NUCON-4, PTEL-5, MRN-1, JR-1, JB-3, STAR-1, SARAF-1	1491
161	25	10 KVA	SUSHIL-6, STAR-2, JR-2, SKYWAY-3, MUSKAN-1, MRN-2, SARAF-2, SHRI.K-1, SIC-3, NUCON-1, NPC-1, BGL-1	1987.2
162	25	10 KVA	NUCON-3, SUSHIL-2, SIC-2, NPC-2, ASI-1, PTEL-3, BANSAL-2, MRN-1, MCPL-1, JB-3, SKYWAY-2, JR-1, SARAF-1, UTTAM-1	1986
180	20	16 KVA	DURABLE-10, SARAF-3, ARD-1, ASI-3, MUSKAN-1, NUCON-1, HR-1	2182
181	20	16 KVA	BGL-3, M.S-1, SKYWAY-1, SARAF-4, JS-1, NUCON-1, DURABLE-6, ASI-2, ECOPOWER-1	2205.9
160	25	10 KVA	SIC-3, PP-2, SUSHIL-2, NUCON-1, NPC-5, PTEL-3, MRN-3, UTTAM-1, SKYWAY-2, JB-2, JR-1	1994.1
178	20	16 KVA	PP-1, DUARABLE-12, SARAF-4, S.S-1, BANSAL-2	2197
Total	210			16986.2

Lot No. A 11 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Barnala

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
188	20	6.3 KVA	PTEL-5, SARAF-1, NPC-7, PP-2, JR-1, JB-3, SIC-1	1198
189	20	6.3 KVA	SIC-4, NUCON-2, PP-1, PTEL-4, JB-2, GTB-1, NPC-4, MAHASHAKTI-1, STAR-1	1202
190	20	6.3 KVA	NPC-4, JB-1, PP-3, SIC-5, PTEL-2, SARAF-1, SUSHIL-1, BANSAL-1, ASI-1, NUCON-1	1194
191	20	6.3 KVA	AMSON-2, SIC-8, NPC-1, NUCON-4, PTEL-2, JB-2, SARAF-1	1193
163	24	10 KVA	SKYWAY-2, STAR-1, DURABLE-1, JB-2, PP-1, PTEL-3, SUSHIL-1, SARAF-2, SIC-2, BGL-3, BANSAL-1, UTTAM-1, NPC-1, SHRI.K-1, ASI-1, DYNAMIC-1	1924.1
164	25	10 KVA	NPC-1, PTEL-3, BGL-2, SIC-4, BANSAL-5, AGGARWAL-2, SKYWAY-2, SARAF-2, MRN-1, UTTAM-1, KISSAN-1, JB-1	1896
182	20	16 KVA	NUCON-2, SARAF-3, UTTAM-2, ARD-1, ASI-2, DURABLE-4, JS-1, PTEL-1, BANSAL-2, NPC-2	2251.6
183	20	16 KVA	DURABLE-3, BANSAL-1, NUCON-1, ARD-1, ECOPOWER-1, NPC-3, SHIVALIK-1, PP-2, BGL-2, SKYWAY-1, SARAF-1, JINDAL-1, ASI-1, TA-1	2185.7
Total	169			13044.4

Lot No. A 12 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Mansa

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
61	25	6.3 KVA	PCE-7, NPC-3, SIC-6, M.SHAKTI-1, PBN-5, PP-3	1487
62	25	6.3 KVA	PCE-6, JKN-1, NPC-3, SIC-6, M.SHAKTI-2, PBN-2, PTEL-4, PP-1	1494
63	25	6.3 KVA	PCE-1, JKN-3, NPC-9, SIC-2, M.SHAKTI-2, PBN-2, PTEL-2, NUCON-1, PP-1, MUSKAN-1, MCPC-1	1483
64	25	6.3 KVA	PEC-1, JKN-1, SUSHI-1, NPC-7, SIC-5, S.WAY-1, JBE-1, M.SHAKTI-2, HI TECH-1, PBN-1, PTEL-1, NUCON-1, PP-2	1475
76	25	16 KVA	M.SHAKTI-5, JR-2, HRPOWER-1, HT-1, NUCON-3, S.KRISHNA-4, SARAF-3, UTTAM-3, AGGARWAL-1, S.SHKATI-2,	2392
82	25	10 KVA	PCE-5, SUSHIL-1, NPC-3,SKYWAY-2,STAR-1, JBE-2,BBN-2,JR-3,PTL-3,NUCON-1,PP-1,PAN-1	1945
	150			10276

Lot No. A 13 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Mansa

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
65	25	6.3 KVA	JKN-3, SUXHIL-1, NPC-7, SIC-2, S.WAY-1, JB-3, M.SHAKTI-3, P.TECH-1, PTEL-1, NUCON-1, AMSON-1, MUSKAN	1427
66	25	6.3 KVA	JKN-1, SUSHIL-1, NPC-12, SIC-2, JBE-4, HI TECH-1, PTEL-1, AMSON-1, PP-2	1506
67	25	6.3 KVA	JKN-2, SUSHIL-3,, NPC-9, JBE-6, M.SHAKTI-1, HI TECH-1, PTEL-1, MUSKAN-1, SIC-1	1519
68	25	6.3 KVA	NPC-5, SIC-3, JBE-5, M.SHAKTI-1, PBN-1, PTEL-1, NUCON-4, S.KRISHNA-1, SARAF-1, PP-2, ASI-1	1443
77	25	16 KVA	NPC-1, M.SHAKTI-3, HI TECH-1, PTEL-2, NUCON-11, S.KRISHNA-1, SARAF-2, P-1, UTAM-2, S.SHAKTI-1	2411
83	25	10 KVA	PCE-1, SIC-2,JBE-11, JR-1, PTEL-1, UTTAM-3,PAN-2,DAUSA-1,AGGARWAL-2, STAR-1	2004
88	25	10 KVA	NPC-1, GTB-2, SIC-3, S.WAY-3, JBE-2, M.SH-1, JR-1, PTEL-4, SARAF-1, PP-1, UTAM-1, PAN-2, MUSKAN-2, ARDISON-1	1975
89	25	10 KVA	SUSHIL-1, SIC-1, S.WAY-2, JBE-3, JR-2, PTEL-1, NUCON-1, S.KRISHNA-1,BANSAL-1, UTTAM-5,	2047
90	25	10 KVA	SUSHIL-1, NPC-1, SIC-1, S.WAY-3, JBE-5, M.SH-1, HR POWER-1, PTEL-1, DURGA-1, S.KRISHNA-1, SARAF-2, UTTAM-1, UPC-1, DYNAMIC-2,	2028
91	23	10 KVA	SUSHIL-3, SIC-1, S.WAY-1, STAR-1, M.SH-1, JR-1, PTEL-2, NUCON-1, SARAF-2, UTTAM-6, PAN-2,	1861
Total	248			18221

Lot No. A 14 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Mansa

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
69	25	6.3 KVA	JKN-1, NPC-6, SIC-2, JBE-6, M.SHAKTI-2, HI TEHC-1, NUCON-1, PP-1, PTEL-5	1492
70	25	6.3 KVA	JKN-1, SUSHIL-1, NPC-2, SIC-2, JBE-5, HTT-1, PTEL-4, NUCON-3, S.KRISHNA-1, SARAF-2, PP-1, MUSKAN-2	1466
71	25	6.3 KVA	SUHSIL-1, NPC-5, SIC-2, S.WAY-2, JBE-5, M.SHAKTI-3, PTEL-4, NUCON-1, S.KRISHNA-1, PP-1	1480
72	25	6.3 KVA	NPC-3, SIC-2, JBE-1, M.SHAKTI-1, PTECH-2, PTEL-10, NUCON-3, PP-2, AMSON-1	1453
78	20	16 KVA	NPC-3, HI TECH-1, NUCON-12, S.SHAKTI-3, DAUSA-1	1954
84	25	10 KVA	SUHSIL-2, GTB-2, SIC-1, S.WAY-1, JBE-5, M.SHAKTI-1, PTEL-2, NUCON-1, STAR-3, PP-2, BANSL-1, UTTAM-1, PAN-2, MUSKAN-1	1916
73	25	6.3 KVA	NPC-6, SIC-2, JBE-3, M.SHAKTI-2, PTEL-5, NUCON-2, S.KRISHNA-1, PP-2, MUSKAN-2	1481
74	25	6.3 KVA	PCE-2, NPC-7, SIC-3, JBE-2, PTECH-1, PTEL-5, NUCON-1, S.KRISHNA-1, SARAF-1, PP-1, TA-1	1483
75	15	6.3 KVA	NPC-2, SIC-1, S.WAY-1, JBE-2, PTECH-2, PTEL-3, NUCON-1, PP-1, TA-2	880
85	25	10 KVA	SUSHIL-2, NPC-1, SIC-5, S.WAY-2, STAR-1, JBE-3, M.SHAKTI-1, S.KRISHNA-2, SARAF-1, UTTAM-3, PAN-2, MUSKAN-2	2015
86	25	10 KVA	SUSHIL-4, NPC-1, SIC-3, STAR-2, JBE-4, HI TECH-1, JR-1, S.KRISHNA-2, SARAF-3, BANSAL-1, PAN-1, MUSKAN-1, M.SHAKTI-1	1951
87	25	10 KVA	SUSHIL-1, NPC-1, SIC-1, S.WAY-2, STAR-1, JBE-3, M.SH-1, JR-3, NUCON-1, S.KRISHNA-1, SARAF-3, JP-1, PP-2, UTTAM-4	2015
Total	285			19586

Lot No. A 15 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Ropar

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
117	25	10 KVA	PTL-4, NPC-4, NSL-1, UBE-2, PPI-4, SUS-1, SIC-3, MKN-2, STB-1, EPS-1, SHIVALIK-1, HIJ-1	2049
121	25	10 KVA	SIC-2, UBE-6, ECN-1, PPI-3, PTL-2, ADN-1, NPC-3, NSL-4, SEF-2, STB-1	2053
118	25	6.3 KVA	MRN-2, PTL-5, SIC-5, STAR-1, NLP-3, AMN-1, NSL-4, HIJ-2, S.WAY-1, NPC-1	1555
119	25	6.3 KVA	SIC-8, PTL-8, NPC-3, NSL-1, AMN-2, PPI-1, SHIVALIK-1, MSK-1	1619
129	25	6.3 KVA	NPC-6, SIC-4, HIJ-2, NSL-7, PTL-2, KSN-1, GTB-1, BGN-1, AMS-1	1583
122	25	16 KVA	PPI-10, NSL-3, PBN-2, SIC-1, UBE-2, ADN-1, JBE-2, NPC-1, PTL-2, SEN-1	2695
Total	150			11554

Lot No. A 16 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Sangrur

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
181	20	10 KVA	SIC-4, PAN-2, NPC-4, PTEL-2, JK-2, HR-3, S.WAY-2, JB-1	1582
182	20	10 KVA	JK-1, SUSHIL-3, UTTAM-1, S.WAY-4, PTEL-1, PAN-1, BANSAL-2, AMSON-1, NPC-1, SIC-2, HR-2, MS-1	1407
183	20	10 KVA	NPC-5, JR-2, S.WAY-3, SUSHIL-1, JB-1, HR-2, S.KRISHNA-1, BGL-2, PPI-1, PTEL-2	1477
184	20	10 KVA	SUSHIL-1, JB-2, ARDISON-1, DURGA-1, PTEL-1, JR-1, GTB-1, SIC-7, HR-2, MS-3	1599
185	20	10 KVA	SUHIL-1, JB-2, SARAF-1, NPC-1, PTEL-1, UTTAM-1, SIC-4, HR-6, MS-3	1620
186	20	10 KVA	SUSHIL-1, HI TEHC-2, NUCON-3, ECO-1, PTEL-1, UTTAM-2, SIC-4, HR-2, MS-2, SK-1, JR-1	1590
187	20	10 KVA	MS-2, DURABLE-1, JB-2, SIC-5, BGEL-1, SARAF-1, NPC-1, HR-1, HI TEHC-2, PAN-1, PPI-1, GTB-1, UTTAM-1	1552
188	20	10 KVA	PTEL-2, SK-4, SIC-4, HI TEHC-1, S.WAY-3, HR-2, UTTAM-1, ARDISON-1, AGGARWAL-1, PAN-1	1603
189	20	10 KVA	SIC-1, UTTAM-1, SARAF-1, PTEL-3, JB-2, SK-2, ARDISON-1, NPC-3, SUSHIL-2, HR-1, GTB-1, MS-2	1620
190	20	10 KVA	SIC-4, UTTAM-3, PPI-1, PTEL-3, JB-1, S.WAY-1, NPC-4, SUSHIL-1, HR-1, MS-1	1573
191	20	10 KVA	KISSAN-1, DURGA-1, UTTAM-2, SIC-4, MS-2, S.WAY-3, GTB-1, DURABLE-1, SUSHIL-1, NUCON-1, JB-1, HI TECH-1, ARDISON-1	1616
192	20	10 KVA	JR-1, NUCON-3, SK-1, ARDISON-2, SIC-2, UTTAM-3, GTB-2, PTEL-1, JB-1, DYNAMIC-1, NPC-1, PPI-1, SARAF-1	1614
193	20	10 KVA	HR-4, SIC-6, GTB-1, PTEL-1, DYNAMIC-2, JR-1, ARDISON-2, MS-1, STAR-1, JB-1	1602
194	14	10 KVA	HR-4, MS-1, UTTAM-1, SIC-3, PTEL-3, JB-1, PPI-1	1115
195	20	6.3 KVA	NPC-2, JB-3, MS-4, S.WAY-1, SIC-4, PTEL-3, MUSKAN-1, STAR-2	1208
196	20	6.3 KVA	SIC-6, STAR-2, PTEL-4, JB-1, NPC-1, AMSON-1, MS-4, SARAF-1	1201
197	20	6.3 KVA	SIC-3, NUCON-2, PTEL-3, STAR-2, NPC-1, JK-1, MS-3, PP-1, JB-4	1216
198	20	6.3 KVA	SIC-4, NUCON-1, PTEL-1, HI TECH-2, NPC-6, AGGARWAL-1, MS-3, PPI-1, DURABLE-1	1209
199	20	6.3 KVA	SIC-3, NUCON-2, PTEL-4, SARAF-3, AMSON-1, HR-1, MS-4, S.WAY-1, JB-1	1219
200	20	6.3 KVA	SIC-3, NUCON-2, PTEL-2, JB-3, NPC-2, SHIVA-1, MS-2, JB-2, SARAF-1, JK-1, HR-1	1218
201	20	6.3 KVA	SIC-1, GTB-1, PTEL-3, STAR-2, MUSKAN-2, AMSON-1, MS-5, PPI-2, JB-1, DURABLE-2	1200
202	20	6.3 KVA	SIC-3, NUCON-1, PTEL-5, HR-1, NPC-3, GTB-2, MS-2, PPI-1, MUSKAN-1, S.WAY-1	1205
	434			31246

Lot No. A 17 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Bathinda

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
142	25	10 KVA	JKN-2, SUSHIL-2, GTB-2, STAR-1, JBE-4, M.S.-1, PBN-1, HTT-2, PTEL-4, NUCON-1, S.KRISHNA-3, BANSAL-1, MUSKAN-1,	1994
143	25	16 KVA	SIC-1, M.S.-1, NUCON-8, S.KRISHNA-2, UTTAM-6, NSL-2, S.SHAKTI-5	2753
144	22	16 KVA	NPC-2, JB-2, M.S.-2, DURABLE-1, HI TECH-1, JR-1, NUCON-4, S.KRISHNA-1, UTTAM-2, TA-1, S.SHAKTI-3, ARDISON-1, DAUSA-1	2362
154	25	6.3 KVA	NPC-5, GTB-3, SIC-5, JBE-1, M.S.-2, HITECH-1, PTEL-4, NUCON-1, S.KRISHNA-1, SARAF-1, PP-1	1497
155	25	6.3 KVA	JKN-1, NPC-1, GTB-3, JBE-2, M.S.-1, TA-2, JR-1, HI POWER-3, PTEL-6, NUCON-2, AMSON-1, S.KRISHNA-1, SARAF-1	1470
156	25	6.3KVA	SUSHIL-1, NPC-4, GTB-1, SIC-1, M,SKT-3, TA-2, JR-5, HRPOWER-1, PTEL-2, NUCON-1, S.KRISHANA-1, SARF-1, PP-2,	1411
	147			11487

Lot No. A18 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY NABHA

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
4./13	20	6.3 KVA	NUCON-2, PTEL-7, NPC-5, NBG-1, BGL-1, JAYBEE-1, SIC-3	1077
5./13	25	10 KVA	NUCON-7, PTEL-1, SIC-2, PP-2, S.WAY-1, ARDISON-7, PAN-1, ECO-1, SUSHIL-1, S.KRISHNA-1, UTTAM-1	1977
6./13	25	10 KVA	NUCON-3, NPC-1, PTEL-2, SIC-5, ARDISON-5, PAN-2, SUSHIL-1, S.KRISHNA-1, UTTAM-3, MUSKAN-1, AMSON-1	1959
7./13	25	10 KVA	NPC-1, NUCON-1, PTEL-2, ARDISON-10, S.KRISHNA-1, UTTAM-1, HI TEHC-1, JB-3, SIC-3, MUSKAN-2	1923
8./13	21	10 KVA	S.KRISHNA-1, ARDISON-5, SIC-2, PP-1, NUCON-3, ECO-1, PTEL-1, AGGARWAL-1, SUSHIL-2, S.WAY-2, UTTAM-1, JK-1	1664
9./13	25	16 KVA	NUCON-7, PTEL-6, UTTAM-3, SIC-2, AGGARWAL-1, ARDISON-1, SARAF-1, S.WAY-2, PP-1, HI TECH-1	2785
10./13	25	16 KVA	NUCON-4, PTEL-1, AGGARWAL-6, ARDISON-9, S.WAY-2, NPC-1, S.SHAKTI-1, TA-1	2670
11./13	25	16 KVA	TA-1, ARDISON-8, SIC-2, S.WAY-9, UTTAM-1, S.SHAKTI-1, PP-1, NPC-2	2737
12./13	25	16 KVA	NUCON-2, S.WAY-10, AGGARWAL-3, ARDISON-5, UTTAM-1, SIC-1, PP-1, JB-1, PTEL-1	2714
13/2013	9	16 KVA	S.WAY-3, PP-1, TA-1, ARDISON-2, AGGARWAL-1, NUCON-1	980
	225			20486

Lot No. A 19 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY Patiala

S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
1334	25	16 KVA	PTEL-13, S.SHAKTI-1, SIC-6, NSL-1, ARDISON-1, NPS-1, S.KRISHNA-1, PP-1	3073
1335	25	16 KVA	NSL-3, PTEL-9, NPC-1, SIC-5, SE-4, M.S.-1, S.S-2	2962
1336	23	16 KVA	SIC-6, JB-1, SE-2, SBI-3, PTEL-7, NSL-2, TA-2	2759
1341	25	16 KVA	NSL-3, JB-2, PTEL-10, SIC-8, NPC-1, SE-1	3066
1342	25	16 KVA	PTEL-9, SIC-6, NPC-1, M.SHAKTI-1, ARDISON-3, SBI-1, PP-1, JB-2, TA-1	3093
1343	26	16 KVA	SIC-5, PTEL-9, S.SHAKTI-1, NPC-1, UTTAM-4, HI TECH-3, ARDISON-1, NSL-2	3111
1337	25	10 KVA	SE-4, PTEL-8, SIC-4, NPC-3, NSL-1, S.KRISHNA-1, JR-1, HITECH-1, GAGAN-1, S.WAY-1	2082
1338	25	10 KVA	PP-4, SIC-6, PTEL-2, NSL-2, GTB-2, JR-1, HI TEHC-1, S.KRISHNA-2, SBI-1, JK-1, M.SHAKTI-1, NPC-1, JB-1	2056
1339	25	10 KVA	SIC-3, UTTAM-3, PTEL-2, NSL-3, NPC-5, PP-2, S.WAY-2, SE-1, PAN-2, M.SHAKTI-1, JB-1	2062
1340	26	10 KVA	SIC-4, PP-2, M.SHAKTI-5, HI TEHC-2, UTTAM-3, NPC-3, JK-1, PTEL-1, NSL-3, PAN-1, GTB-1	2197
1344	26	6.3 KVA	NSL-4, SE-1, PTEL-3, NPC-7, SIC-3, ARDISON-3, BGL-1, SHIV-1, STAR-1, AMSON-1, M.SHAKTI-1	1608
1345	26	6.3 KVA	ARDISON-1, NPS-6, M.SHAKTI-2, NSL-6, STAR-2, AMSON-3, PTEL-3, GTB-1, SIC-2	1604
1346	27	6.3 KVA	AMSON-2, NPC-6, NSL-6, PTEL-4, SIC-3, STAR-2, M.SHAKTI-3, GTB-1	1667
	329			31340

Lot No. A 20 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY KOTKAPURA				
S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
KKK 61/12	20	6.3 KVA	JB-2, JM-2, JR-4, HRPOWER-4, MRN-4, SEF-2, NPC-2	1209
KKK 62/12	20	6.3 KVA	MRN-3, PTEL-4, JB-3, DTPL-1, NPC-3, PP-1, HRPOWER-3, NSL-1, JM-1	1202.7
KKK 63/12	20	6.3 KVA	MRN-2, UBE-1, SIC-3, PTEL-3, JR-7, JB-1, JM-2, NSL-1	1179
KKK 64/12	20	6.3 KVA	JB-1, JR-10, MRN-2, PAN-1, HRPOWER-1, DTPL-1, NPC-1, SIC-2, NSL-1	1181.7
KKK 65/12	20	6.3 KVA	JR-8, DTPL-1, NPC-3, MRN-1, JB-4, PP-1, JM-2	1203.7
KKK 66/12	20	6.3 KVA	JB-2, MRN-2, JR-6, JM-6, HRPOWER-2, NPC-1, SEF-1	1194
KKK 67/12	20	6.3 KVA	MRN-1, HRPOWER-6, SIC-2, JR-4, JM-1, SEF-1, DTPL-3, JB-1, PTEL-1	1204.5
KKK 68/12	20	6.3 KVA	JB-1, MRN-2, HRPOWER-2, DTPL-4, NSL-1, JR-4, NPC-3, PP-2, SHIWALIK-1	1191.2
KKK 69/12	20	6.3 KVA	JM-5, STAR-1, PTEL-1, JB-3, SEF-1, DTPL-3, HTT-1, JR-5	1193.8
KKK 70/12	20	6.3 KVA	MRN-3, JR-7, JM-2, SEF-3, DTPL-2, NPC-1, STAR-1, JB-1	1196.4
KKK 71/12	20	6.3 KVA	JM-1, JR-4, PTEL-2, NPC-2, MRN-2, JB-1, PP-1, JK-1, SIC-3, SEF-2, DTPL-1	1192
KKK 72/12	20	6.3 KVA	JB-2, SIC-2, DTPL-1, NPC-4, PP-1, HRPOWER-2, MRN-3, JM-2, SHIWALIK-1, JR-2	1220.4
KKK 73/12	20	6.3 KVA	MRN-5, PP-4, JR-4, SKSU-2, HRPOWER-1, JM-1, SEF-1, DTPL-2	1177.4
KKK 74/12	20	6.3 KVA	NPC-1, JR-2, MRN-4, DTPL-2, SHIVALIK-3, AGGARWAL-1, SEF-4, JB-2, JM-1	1176.1
KKK 75/12	20	6.3 KVA	SHIVALIK-1, SEF-1, PP-1, HRPOWER-3, PTEL-2, JR-6, NSL-1, DTPL-1, JM-1, ARDISON-1, MRN-1, JB-1	1156.4
	300			17878.3

Lot No. A 21 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY MOGA				
S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
SRM/100/13	20	16 KVA	PPI-1, S.SHAHTI-5, NUCON-6, JR-2, PTEL-2, UTTAM-1, MUSKAN-2, TA-1	2306
SRM/101/13	20	16 KVA	PTEL-10, S.SHAHTI-2, UTTAM-1, PPI-1, NUCON-1, TA-1, SARAF-1, DURABLE-2, NPC-1	2155
SRM/106/13	20	6.3KVA	STAR-1, SICL-5, S.WAY-1, PPI-5, NUCON-4, PTEL-4	1111
SRM/107/13	20	6.3KVA	P.TECH-1, SICL-7, NUCON-7, TA-3, ARDISON-1, JBE-1	1137
SRM/55/12	20	6.3KVA	SICL-8, PTEL-3, GTB-1, STAR-1, JBE-3, NUCON-1, NPC-1, MCPL-1, PPI-1	1160
SRM/53/12	20	6.3KVA	NPC-3, PTEL-4, JBE-2, PPI-4, SUSHIL-1, SICL-3, TA-1, NUCON-1, P.TECH-1	1163
	120			9032

Lot No. A 22 Copper Wound Damaged Distribution Transformers Without oil along with accessories as per actual site condition lying at TRY MOGA				
S.Report No.	No of T/Fs	Cap. in KVA	Description	Indicative Design Wt. of Core & Winding (KG)
SRM/109/13	20	10 KVA	SARAF-2, SICL-7, JMI-2, S.WAY-1, SUSHIL-3, JBE-1, PTEL-1, UTTAM-2, AGGARWAL-1	1580
SRM/110/13	2	10 KVA	S.WAY-1, PTEL-1	166
SRM/108/13	20	10KVA	JR-1, SICL-10, NPC-1, SUSHIL-1, UTTAM-2, S.SHAHTI-1, JMI-3, PPI-1	1583
SRM/54/12	20	6.3KVA	MUSKAN-1, S.WAY-2, NUCON-3, SICL-5, NPC-4, PTEL-1, PBN-2, STAR-1, JBE-1	1192
SRM/56/12	20	6.3KVA	JBE-2, NPC-5, PPI-3, PBN-2, STAR-1, SICL-3, PTEL-1, SUSHIL-1, MRN-1, PIT-1	1210
SRM/57/12	20	6.3KVA	SICL-4, NUCON-3, NPC-4, JBE-2, PTEL-3, SUSHIL-1, PPI-3	1182
SRM/58/12	20	6.3KVA	SICL-5, NPC-4, JBE-5, PPI-2, NUCON-2, S.WAY-1, PTEL-1	1163
SRM/59/12	20	6.3KVA	NUCON-2, PPI-8, SICL-2, PTEL-3, JBE-1, MUSKAN-1, STAR-1, PBN-2	1145
SRM/60/12	20	6.3KVA	NPC-3, JBE-6, PTT-1, PPI-1, SUSHIL-1, PTEL-1, SICL-3, NUCON-3, MUSKAN-1	1229
SRM/61/12	20	6.3KVA	JBE-2, SICL-8, NPC-4, PPI-2, SUSHIL-1, MUSKAN-1, PTT-1, S.WAY-1	1189
SRM/62/12	5	6.3KVA	PCE-2, NPC-1, PPC-1, SICL-1	285
SRM/102/13	20	16 KVA	TA-1, JR-3, PTEL-5, NUCON-6, MUSKAN-4, M.S.-1	2116
SRM/103/13	20	16 KVA	JR-1, NPC-3, NUCON-5, PTEL-5, TA-3, MUSKAN-1, DURABLE-1, JBE-1	2108
SRM/104/13	20	16 KVA	DURABLE-2, NUCON-8, PTEL-7, S.SHAHTI-1, UTTAM-1, S.KRISHAN-1	2098
SRM/105/13	16	16 KVA	SARAF-1, HI TEHC-1, NPC-2, PTEL-7, UTTAM-1, TA-2, DURABLE-1, MUSKAN-1	1743
SRM/63/12	20	6.3KVA	PTEL-4, PP-2, NSL-3, SUSHIL-1, TA-1, SIC-6, NPC-2, DTPL-1	1205
SRM/64/12	10	6.3KVA	PTEL-2, PP-2, SIC-4, GTB-1, NSL-1	590
	293			21784

B - Damaged Distribution Transformer's HT/LT Aluminium coils scrap with insulation

Lot No.	Name of Store where material is lying	Quantity in MT
Lot no.B 1	TRY, Kotkapura (No. of days for payment / lifting - 45 days/ 60 days)	155.0
Lot no.B 2	TRY , Ferozepur	136.0
Lot no.B 3	TRY , Malout	41.0
Lot no.B 4	TRY, Sangrur	35.0
Lot no.B 5	TRY Ropar	20.0
Lot no.B 6	TRY Patiala	26.0
Lot no.B 7	TRY Nabha	12.5
Lot no.B 8	TRY Patran	20.0
Lot no.B 9	TRY Barnala	19.5
Lot no.B 10	TRY Moga	24.0
Lot no.B 11	TRY Bathinda	13.5
Lot no.B 12	TRY Mansa	15.0

C- Aluminium Cables scrap as per detail given below -

Aluminium Cables scrap			34.705 MT
Lot No.	Name of Store	Description of material	Quantity in MT
Lot no. C - 1	Patiala	2/Core PVC Aluminium Cable	19,300
		4/Core PVC Aluminium Cable	10,560
		3/Core XLPE Cable	3,550
		U/G Alum. Cable scrap	1,295

Aluminium Cables scrap			32.063 MT
Lot No.	Name of Store	Description of material	Quantity in MT
Lot no. C - 2	Kotkapura	1/Core PVC Aluminium Cable	0.190
		2/Core PVC Aluminium Cable	20.140
		4/Core PVC Aluminium Cable	6.158
		3/Core XLPE Cable	4.295
		U/G Alum. Cable scrap	1.280

D - Miscellaneous Iron scrap as per detail given below -

Miscellaneous Iron scrap			30.357 MT
Lot No.	Name of Store	Description of material	Quantity in MT
Lot no. D - 1	Ropar	M.S Iron Scrap	12.905
		M S Rail Scrap	4.826
		MS Girder scrap	0.170
		T/F Body scrap	4.695
		GI Wire/GSL Scrap	5.491
		Lamination scrap	2.270

E - Aluminium Conductor Steel Reinforced Scrap

Lot No.	Name of Store where material is lying	Quantity in MT
Lot no. E 1	Central Store, Kotkapura	30.0
Lot no. E 2	Central Store, Ferozepur	75.0
Lot no. E 3	Central Store, Malout	58.0
Lot no. E 4	Central Store, Bathinda	25.0
Lot no. E 5	Central Store, Patiala	20.0
Lot no. E 6	Central Store, Mansa	40.0

F - Following machines lying at Central Store, Patiala as per detail given :-

Description of material	Quantity
1 Lathe machine	2 No.
2 Heavy duty drilling Machine fitted with motors	3 Nos.
3 Electric shapper	1 No.
4 Hand Press Machine	2 No.
5 Power Hacksaw	1 No.

The approximate weight of the above said machines (1 to 5) is 3.5 MT. However actual weight of the lot shall be taken at the time of lifting of material by the firm and the excess / shortfall in the payment shall be adjusted accordingly at the time of lifting of material.

G - Following Misc. scrap / Unserviceable items lying at Central Store, Patiala as per detail given :-

Description of material	Quantity
1 Unserviceable CT	67 Nos.
2 Unserviceable AC	5 Nos.
3 Unserviceable Typewriters	31 Nos.
4 Unserviceable Ceiling Fans	43 Nos.
5 Radiator scrap	1 No.
6 Aluminium seals with lash wire scrap	2.025 MT
7 Empty plastic cans (cap. 5 ltrs.)	3000 Nos.
8 Empty Wooden reels / drums (lying at Coil Fabrication cell, Patiala).	1000/170 Nos.

Lot No.	Registration no. of Vehicle	Type of vehicle/ Model	Present Location of vehicle	Name of the office to which it relates/ Phone no. of the person to be contacted.
H-1	PBW 868	Ambassador car/1981	Irr. works , New building.Sec-18-B, Chandigarh	Director, Hydel Design Orgn, Sec-18-B, Chandigarh./ 98761 60624
H-2	PB 05 D 9499	Pickup / 1996	33 KV S/Stn. (Op) S/Divn, Mudaki	(op) City Divn, Ferozpur Cantt./ 9646118856
H-3	PB-10 AF-9702	Swaraj Mazda / 1998	Op S/Divn, Kohara	Op S/Divn, Kohara./ 9646110127
H-4	PB 11 P 9390	Ambassador car/2000	Shakti Sadan, Patiala	Sr. Xen /Civil Tech. Audit, Patiala / 9646119591
H-5	PB-11-X-8283	Ambassador Car/2003	Rest House, Sri Mukatsar sahib	Addl SE (op), Sri Mukatsar Sahib / 9646114529
H-6	PB-03-E-130	Ambassador Car/1996	132 KV S/Stn. Sri Mukatsar sahib	Addl SE (op), Sri Mukatsar Sahib / 9646114529
H-7	PUV-9110	Truck/1975	33 KV S/Stn. Abohar	S/D No.1 Abohar / 9646114528
H-8	PUD-2673	M&M jeep/1984	Op S/Divn, Sardulgarh	Op S/Divn, Sardulgarh / 9646114765
H-9	PB-11-C-9897	Ambassador Car	66 KV Grid S/Stn,Civil lines, Bathinda	Op S/Divn, Tech-1, Bathidna / 9646114541
H-10	PB-04-2113	Matadoor/ 1989	(op) S/Divn, Bilaspur	Op/Divn, Bagha Purana / 9646114581

I - Aluminium Conductor Steel Reinforced Scrap

Lot No.	Name of Store where material is lying	Quantity in MT
Lot no. 1 -1	Central Store, Kotkapura	45.0
Lot no. 1 -2	Central Store, Bathinda	25.0
Lot no. 1 -3	Central Store, Patiala	20.0
Lot no. 1 -4	Central Store, Mansa	20.0